

COVER LETTER

Feb 10 2023

Certificate Holder: Integrated Gas Technologies ApS
Address: Gydevang 39-41, DK-3450, Allerød, Denmark

Your Ref. SDHL2207014295GA

Dear Customer,

We enclose
Certificate 2531-GAR-CGC10191

This certificate applies to the product that has been tested by SGS and certified by DBIC according to our conditions for certification. We ask you to contact us in possible changes to the product (e.g. component, other construction, trade name or type changes) or to the certificate in order to let us ensure the continued validity of the certificate.

For more information on this certificate, please contact us.

Yours sincerely,
SGS-CSTC Standards Technical Services Co., Ltd.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

15/F, Building European Industrial Park No.1 Shunde South Road, Wusheng Section, Daliang Town, Shunde, Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgs.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园15楼 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

MODULE B: EU TYPE-EXAMINATION – PRODUCTION TYPE

Issued by DBI Certification, notified body no. 2531

The equipment identified below was found to comply with the Essential Requirements of the Regulation of Appliances burning gaseous fuels (EU) 2016/426 Annex I.

Manufacturer	Integrated Gas Technologies ApS
Address	Gydevang 39-41, DK-3450, Allerød, Denmark
Type of Appliance	Low Pressure Gas Regulator
Trademark	IGT
Pin Code	2531CS-0134
Specified Standards	EN 12864:2001+A1:2003+A2:2005+A3:2009 (WITHDRAWN) & EN 16129:2013
Issue Date	2023-02-10
Expiration Date	2028-04-21
First Issued	2018-04-21

This certificate supersedes the certificate issued: 2021-07-27 by NB no. 2531

Signed		
Name	Ken Olesen Responsible for evaluation	Jesper Viggo Quaade Responsible for certification decision

Note:
This certificate will not be valid if the manufacturer makes any modifications to the approved equipment without the approval of DBI Certification A/S.
The CE Mark of Conformity may only be affixed to the above type approved equipment and a Manufacturer’s Declaration of Conformity issued, when the production control phase module (C2, D, E, F or G) is fully complied with and documented by an inspection agreement with a notified body.
This certificate remains valid unless suspended, withdrawn, or expired, provided the conditions in the attached description are complied with and the equipment remains satisfactory in service.

Model	BGR
-------	-----

Test reports	SGS test report SDHL1711024304GA: 2017-12-27. Amendment-1: 2019-06-25 Amendment-2: 2021-07-08 Amendment-3: 2023-01-30
--------------	--

Gas Type	Propane	LPG	LPG
Working temperature	(-20 ~ +50) °C	(-20 ~ +50) °C	(-20 ~ +50) °C
Inlet pressure	(1 ~ 16) bar	(0.3 ~ 16) bar	(0.3 ~ 16) bar
Outlet pressure	37 mbar	(28-30)mbar	(28-30) mbar
Flow rate	2.0 kg/h	2.0 kg/h	0.3 kg/h
Inlet / outlet	Inlet: G56 Outlet: All relevant according to EN 16129:2013		

End of Certificate